



Phone : 23704371

GOVT. OF INDIA
MSME TESTING STATION
(Formerly Field Testing Station)
MINISTRY OF MICRO, SMALL & MEDIUM ENTERPRISES
A1, Industrial Estate, Sanathnagar, Hyderabad - 500 018.

TEST REPORT

Date : 10.02.2023

1. Name & Address of the Customer : M/s Aerolite Industries Pvt. Ltd.,
Mekaguda Village ,
Nandigama Mandal.
54963
2. Test Report No. : 54963
3. Job Order No. & Date : dt. 03.01.2023
4. Specimen reference No. : _____
5. Specimen's material & condition : Calcium Silicate
6. Type of test & method of test : SAG Resistance
7. Date of performance of test : 13.01.2023
8. Equipment used : As required
9. Test results :

Sl.No.	Name of the Test	Test Method	Result
1	SAG Resistance test	ASTM C 473-03	No Sagging

Note: Tested as per Standards and above tests are witnessed at M/s KELVN Labs,
IDA Nacharam, Hyderabad.



Any erasure/correction in the results invalidates this report. The test result pertains only to the Specimen tested.
This test report should not be reproduced on partial / full without written approval from the Incharge of the Station.
Sampling is not undertaken by this office. Sample ID/PO/ISO are declared by the customer, same is reproduced.

Authorised Signatory