



SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A unit of Shriram Scientific and Industrial Research Foundation)

19, University Road, Delhi – 110007 (India)
An ISO - 9001, 14001 & OHSAS 18001 Certified Institute

Website : www.shriraminstitute.org
E-mail id : customercare@shriraminstitute.org

TEST CERTIFICATE

NO : C1/0000215314

Issued To :

Client Code : (RRDT01A2139)

AEROLITE INDUSTRIES PVT. LTD.

SY NO. 918/A, PART 918/C PART 918/B/1 PART 919/C PART 919/B/4,

MEKAGUDA VILLAGE, NANDIGAMA MANDAL

RANGAREDDI DISTRICT

TELANGANA-509223

Kind Attn: MR. SHREYANS KHEMKA, MD

Date : 30-04-2020

Job No : 2003-1-111-312

Booking No : RG1920/1/15022

Booking Date : 03-03-2020

Customer Ref No. : JOB ORDER NO. - AIPL/JOB/178

Customer Ref Dt. : 25-02-2020

Sample Particulars:

One sample of Calcium Silicate False Ceiling Tiles brand "AEROLITE" full size tile of 595 x 595 mm of nominal thickness - 15 mm (with Bio-Safe), marked as 'Sample A', Ref No: Aerolite Ceiling, Systems/21012020 was received.

"The sampling was not carried out by Shriram Institute for Industrial Research. The sample details provided in test certificate are based on declaration by the party."

Product Details- Calcium Silicate False Ceiling Tiles brand "AEROLITE"

Test- Fungal Resistance

Protocol- As per ASTM G-21-15

Test Organisms- *Aspergillus niger*, *Aureobasidium pullulans*, *Penicillium pinophilum*,
Chaetomium globosum, *Trichoderma virens*

Time of Incubation- 28⁰ C for 28 days

TEST RESULTS

S.No.	Observed growth on Specimen	Rating
1	None	0

Interpretation: Result rating 0, for the test specimen As per G-21. As no fungal growth observed on the test specimen, hence, we confirm the sample passes the test in this regard.

DOR: 03.03.2020

DOC: 30.04.2020

AUTHORISED SIGNATORY

EMPLOYEE CODE:(6192)

GC-01(Rev-05)

1/1

Scanned copies/photocopies or any other copies should be authenticated by reference to the original report.

Phone : 91-11-27000100, 27667267, 27667860

Fax : 91-11-27667207

See overleaf for terms & conditions

SRI-C1 (Rev. 03)